

## BMP Summary Sheet

**MS4 Name:** University of Minnesota, Twin Cities

**Minimum Control Measure:** 6-POLLUTION PREVENTION/GOOD HOUSEKEEPING

**Unique BMP Identification Number:** 6A.14 (MS4 2020: 21.4.c)

**BMP Title:** Fueling System Spill Protection

**BMP Description:**

The University utilizes Underground and Above Ground Storage Tanks (USTs and ASTs) for vehicle and equipment fueling, which are included on the Facilities Inventory Map. Each outdoor fueling station is equipped with spill response supplies and UST systems are also equipped with a spill bucket and overfill protection in accordance with MPCA Rules. ASTs are included in the University's SPCC Program which includes monthly container integrity inspections and personnel training.

This is a University-wide BMP.

**Measurable Goals:**

Maintain spill response supplies at fueling sites

**Timeline/Implementation Schedule:**

N/A

**Specific Components and Notes:**

Facilities Inventory Map/List  
HSRM Spill Response Program/SPCC Plan  
BMP 6A.15 Vehicle Storage and Maintenance  
BMP 6A.16 Equipment Storage and Maintenance

**Responsible Party for this BMP:**

Name: Linnea Weum

Department: Environmental Affairs & Compliance Administrator, Health, Safety, and Risk Management

E-mail: henke079@umn.edu